PASS CERTIFICATE For:

Kingsley Court,
142 Kings Road,
Brighton,
BN1 2LP

Dry Riser Testing South Ltd

1 West Holme Manor Cottages,
Wareham,
Dorset,
BH20 6AQ

Tel: 07818509544/07767458350
Email: p.diffey@drtsouth.com
Web: www.nationaldryrisertesting.co.uk

Date of Test	04/08/2025
Expiry Date	03/08/2026
Pressure reading at start of test at inlet	12 Bar
Pressure reading at start of test at top outlet	11 Bar
Pressure reading at end of test at inlet after 15 mins	11.8 Bar
Pressure reading at end of test at top outlet after 15 mins	10.5 Bar
Number of Floors	5
Type of System	Dry
Flow test reading	N/A
Engineers	RC/JJ
Notes/work/recommendation	Pass

This Certificate is issued to the above property for the riser system in place, on passing the required criteria of an annual pressure test and inspection in accordance with BS9990/2015. This certificate is only valid for 1 year from date of test.

To pass a Static test the system must not drop of more than 1 bar over a period of 15 minutes
this drop maybe due to temperature and resting of water. A flow test where applicable must pass a 500 Lpm flow with 0.1 of every metre of height plus 5.5 bars for a fire fighting jet.

Signed: *P.R. Diffey/J.Jeneson*