Certificate of Test and Inspection

PTSG PREMIER TECHNICAL SERVICES GROUP
Electrical Services Ltd

Certificate Ref	CERSTO328771
Customer	Jonathan Rolls Property
Building Name	Kingsley Court
Site Address	Kingsley Court 142 Kings Road Brighton East Sussex BN1 2LP

PTSG Work Order Reference	WSTO313086
Client Purchase Order	Email confirmation 09/06/2025 Ben Lewis

Pass

System Type: Full System

The Structural Lightning Protection System has been tested in accordance with BS 6651 or BS EN 62305-3. The system is in a satisfactory condition.

Calibration certificates available on request

Tested by:Callum Liddle	Equipment Meg:E8459949

Air Termination Network

Type	Not Visible
Size	N/A
Mesh Size	N/A
Fixings	N/A
Fixing Type	N/A
Bonding Type	N/A

Down Conductor Network

Material	Aluminium
Colour	White
Size	25 x 3mm PVC
Fixings	N/A
Spacing	20m
EQ Bond Fitted	No

Overall System Reading:0.569

Exception on reading:

0 ohms = No Access, No Test or No Reading

EP No.	Resistance in Ohms	Any Comments		Ground Type	Type of Inspection Pit	Type of Electrode	Type of Test Clamp	Test Method
1	40.0	-		Slabs	Concrete	Copper Bond	Stainless Steel	Fall of Potential
2	0.61	-		Slabs	Concrete	Copper Bond	Stainless Steel	Dead earth test
3	15.9	N/A	N/AN/AN/A	Slabs	Concrete	Copper Bond	Stainless Steel	Dead earth test
4	32.7	-		Slabs	Concrete	Copper Bond	Oblong	Fall of Potential

Repair Date:	26/06/2025	Certificate Valid Until:	29/04/2026
Original Date of Test:	30/04/2025	Next Inspection due:	29/03/2026
Test Engineer Name:	Callum Liddle	Engineers Signature	